

RACE STREET PIER
SPECIFICATION CLARIFICATION
SECTION 2.2
MATERIALS
BOOSTER PUMP SYSTEM
AUGUST 31, 2010

2.2

Materials

Booster Pump System

1. Booster pump station to be variable speed packaged pump station rated for 35 GPM @ 45 PSIG boost at station discharge; 3600 RPM 230/1/60 FV, horizontal nema faced ODP motors, model SST-BV-1-3-230-1-35-45 as manufactured by Watertronics.